



Sub Divisional Level Water Quality Testing Laboratory
UTTARAKHAND JAL SANSTHAN
HALDWANI, NAINITAL

| | | | |
|---|---|--------------------------------------|---|
| Name of the Customer/ Organization: | Milton Educational Academy Rampur Road Bilaspur Distt:- Rampur Uttar Pradesh | Sample Description | Milton Educational Academy Rampur Road Bilaspur Distt:- Rampur Uttar Pradesh |
| Type of Water (Surface water/Ground water) | Drinking-Water | Start of analysis End of analysis | 30-05-2026 01-06-2026 |
| Sample Code: | SDLWQTML/UJS/MEA-16 | Sample collected By | Customer |
| Sample Receiving Date and Time: | 30.05.2026 02:30 PM | Date of Issue Report | 01-06-2026 |

Water Quality Test Report
Testing Details

| S.N. | Parameters | Acceptable Limit (As per BIS 10500-2012) | Permissible Limit (in the Absence of alternative source) (As per BIS 10500- 2012) | Results |
|------|--|---|--|-----------|
| 1 | Colour (Hazen units) | 5 | 15 | 1 |
| 2 | Odour (Agreeable) | Agreeable | Agreeable | Agreeable |
| 3 | pH@25*c | 6.5 to 8.5 | No relaxation | 7.42 |
| 4 | Alkalinity as CaCO ₃ (mg/l) | 200 | 600 | 164 |
| 5 | Turbidity (NTU) | 1 | 5 | 0.62 |
| 6 | Total dissolved solid (mg/l) | 500 | 2000 | 243 |
| 7 | Chloride (mg/l) | 250 | 1000 | 3.9 |
| 8 | Total hardness (mg/l) | 200 | 600 | 144 |
| 9 | Calcium(as ca) (mg/l) | 75 | 200 | 45.6 |
| 10 | Magnesium (mg/l) | 30 | 100 | 7.2 |
| 11 | Total coliform (MPN/100ML) | ABSENT | ABSENT | ABSENT |
| 12 | E.Coli (MPN/100.ML) | ABSENT | ABSENT | ABSENT |

S. Singh
CHEMIST,
(Surendra Singh)
SDLWQTML, UJS Haldwani (Nainital)
Chemist

Sub Divisional Level
Water Quality Testing & Monitoring Laboratory
UJS- Haldwani (Nainital)

[Signature]
Technical Manager
In-Charge of Laboratory
UJS Haldwani (Nainital)

TECHNICAL MANAGER
Sub- Divisional Level
Water Quality Testing
& Monitoring Laboratory
UJS- Haldwani (Nainital)



**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. MEA-16Date: 1/06/2026

It is certified that an inspection team headed by Narendra Dugtal Sampling Assistant
(Name of Officers
with designation) from UJS Haldwani Uttarakhand (Name of
Department/Office) inspected the Milton Educational Academy Bilaspur U.P
(Name & Address of
the School) on 30/05/2026 and found that the Milton Educational Academy
(Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 29/05/2026Signature with Seal: [Signature]

Name

: Surendra Singh

Designation

: Chemist

Authorised Signatory
Sub Divisional Level
Quality Testing & Monitoring Laboratory
UJS Haldwani (Nainital)

To

The Principle
Milton Educational Academy
Bilaspur Uttar Pradesh
(Name & Address of the Institution)